

DAILY FIELD REPORT



☒ PO Box 44840, Tacoma, WA 98448
☐ 17921 Bothell Everett Hwy, Ste 102, Bothell, WA 98012

(253) 537-9400 office • (253) 537-9401 fax
 (425) 398-2300 office • (425) 398-2333 fax

PROJECT NAME 5129 227 th Ave SE CM		PROJECT NO. P2106-T20	FIELD REPORT NO. 1
ADDRESS 5129 227 th Ave SE		DATE 06/26/20	PAGE 1 OF 1
CITY OR COUNTY Issaquah	PERMIT NO.	ARRIVAL TIME	DEPARTURE TIME
CLIENT Scott Donogh Homes		MIGIZI PROJECT MANAGER / PHONE NO. James Brigham 253-537-9400	
GENERAL CONTRACTOR Scott Donogh Homes		MIGIZI FIELD REPRESENTATIVE / PHONE NO. Zach Logan 360-689-5810	
SUBCONTRACTOR Kleansweep		WEATHER Clear	
TYPE OF WORK PERFORMED Observe subgrade conditions			
EQUIPMENT USED			

COMMENTS

Migizi Group, Inc. (MGI) onsite at the request of the City of Issaquah to perform special inspections of the drainage installation for the new residence. At the time of our site visit, the foundation and stem walls have been poured, and the contractor is prepping the backfill of the region. Footing drains had been installed along the juncture between the spread footings and stem walls, generally consisting of a 4-inch perforated pipe enveloped in washed rock and filter fabric. It is our understanding that the foundation drains will be tight-lined to an adjacent dispersion system. Foundation drains were installed in general conformance with site plans and specifications, and based upon our field observation, should function as designed.

-End-

The contents of this field report were discussed with the contractor's on-site representative.

☐ A preliminary copy of this field report was left on site. All recommendations contained herein are subject to change pending review by the Migizi project manager.

Migizi Group, Inc., Field Representative

Migizi Group, Inc., Project Manager